

Scope of Work for Property Located at: 2506-08 N 40th St
Property is: Single Family ☐ Duplex ☒ Other ☐ _____

Date: 8/18/2016

Below is the **minimum requirement** to meet health and safety issues. The City of Milwaukee, the Redevelopment Authority, and their representatives take no responsibility for problems discovered after the inspection date, or for omissions through error or oversight. The list does not necessarily include work required by private lenders, insurance companies, or by the Federal Block Grant or HOME programs.

Exterior Condition Report

Location	Required Work	Note/Comments	Cost
Site	Landscaping	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> Cut back trees and overgrowth	\$ 1,200.00
	Steps/Handrails	n/a <input checked="" type="checkbox"/> Yes <input type="checkbox"/>	\$
	Service walks	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/>	\$ 600.00
	Fencing	n/a <input checked="" type="checkbox"/> Yes <input type="checkbox"/>	\$
	Parking	n/a <input checked="" type="checkbox"/> Yes <input type="checkbox"/>	\$
	Retaining walls	n/a <input checked="" type="checkbox"/> Yes <input type="checkbox"/>	\$
	Other	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Other	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Singles: repair	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Shingles: Roof over existing	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Shingles:Tear off & re-roof	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Gutters/downspouts	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Flashing	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Eaves	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
Garage	Siding	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Doors	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Windows	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Slab	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Paint	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Electrical	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Other	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> Raze or repair to code compliant condition	\$ 7,500.00
	Roof	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Upper front porch	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> Complete replacement	\$ 6,000.00
	Lower front porch	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> Complete replacement	\$ 4,500.00
	Rear jump porch	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> Complete replacement	\$ 1,000.00
	Ceiling	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Guardrails	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Structural	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
Porches	Paint	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/>	\$ 1,800.00
	Other	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> permit	\$ 85.00

House

Chimney	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	500.00
Shingles: repair	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	600.00
Shingles: Roof over existing	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Shingles:Tear off & re-roof	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Gutters/downspouts	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	1,500.00
Flashing	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Eaves	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Siding	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	4,500.00
Storm Doors	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Prime ("main") Doors	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	1,050.00
Storm Windows	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Prime ("main") Windows	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	12,400.00
Paint	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	4,000.00
Foundation	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Electrical	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	1,500.00
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	

Exterior: Estimated Cost:* **\$ 48,735.00**

*average contracted cost. Actual costs may vary. Self help will reduce the amount.

Interior Condition Report

Unit: Entire unit (single family) ☐

Lower unit of duplex ☒

Upper unit of duplex ☐

Other ☐

Mechanical

Required Work

Heating

Repair/replace boiler	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair radiation	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace furnace	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	3,080.00
Repair ductwork	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	750.00
Replace thermostat	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	100.00
Repair/replace grilles	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Other	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	permit	\$ 85.00

Electrical

Repair/replace receptacles	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	750.00
Repair/replace switches	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	750.00
Repair/replace fixtures	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	750.00
Install outlets and circuits	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Install outlets and circuits	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Install outlets and circuits	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Install outlets and circuits	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Upgrade service	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	2,100.00
Other	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	permit	\$ 85.00
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	

Plumbing

Kitchen	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	Complete replacement	\$ 1,750.00
Bathroom	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	Complete replacement	\$ 2,250.00
Repair/replace tub	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace tub faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace toilet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace lavatory	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace lavatory faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace wash tub	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace wash tub faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Unclog piping:	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair drain/waste/vent piping	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	850.00
Repair water piping	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	800.00
Repair/replace water heater	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	1,300.00
Other	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	permit	\$ 85.00
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	

Windows

Replace broken glass	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$
----------------------	-----	-------------------------------------	-----	--------------------------	----

Repair or replace sash	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$
------------------------	-----	-------------------------------------	-----	--------------------------	----

Doors

Repair or replace doors	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	1,200.00
-------------------------	-----	--------------------------	-----	-------------------------------------	----	----------

Repair or repl. locks/latches	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	<i>Self Help</i>	\$	330.00
-------------------------------	-----	--------------------------	-----	-------------------------------------	------------------	----	--------

Walls/Ceilings

Repair or repl. @ defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	2,000.00
-----------------------------	-----	--------------------------	-----	-------------------------------------	----	----------

Paint

Repair or repl. @ defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	1,000.00
-----------------------------	-----	--------------------------	-----	-------------------------------------	----	----------

Fire Safety

Install smoke/CO alarm:bsmt.	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	<i>Self Help</i>	\$	85.00
------------------------------	-----	--------------------------	-----	-------------------------------------	------------------	----	-------

Install smoke/CO alarm: 1st flr.	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	<i>Self Help</i>	\$	170.00
----------------------------------	-----	--------------------------	-----	-------------------------------------	------------------	----	--------

Install smoke/CO alarm: 2nd flr.	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	<i>Self Help</i>	\$
----------------------------------	-----	-------------------------------------	-----	--------------------------	------------------	----

Handrails

Repair/replace defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	<i>Self Help</i>	\$	250.00
--------------------------	-----	--------------------------	-----	-------------------------------------	------------------	----	--------

Stairs

Repair defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	850.00
------------------	-----	--------------------------	-----	-------------------------------------	----	--------

Floors

Repair defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	1,500.00
------------------	-----	--------------------------	-----	-------------------------------------	----	----------

Other

	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	Basement toilet - remove or replace	\$	350.00
--	-----	--------------------------	-----	-------------------------------------	-------------------------------------	----	--------

	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>		\$
--	-----	--------------------------	-----	--------------------------	--	----

	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>		\$
--	-----	--------------------------	-----	--------------------------	--	----

	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>		\$
--	-----	--------------------------	-----	--------------------------	--	----

Interior Condition Report

Unit: Entire unit (single family) ☐
Upper unit of duplex ☒

Lower unit of duplex ☐
Other ☐

Mechanical Heating

Required Work

Repair/replace boiler	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair radiation	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace furnace	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	3,080.00
Repair ductwork	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	750.00
Replace thermostat	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	100.00
Repair/replace grilles	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Other	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	permit	\$ 85.00

Electrical

Repair/replace receptacles	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	750.00
Repair/replace switches	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	750.00
Repair/replace fixtures	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	750.00
Install outlets and circuits	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Install outlets and circuits	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Install outlets and circuits	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Install outlets and circuits	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Upgrade service	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	2,100.00
Other	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	permit	\$ 85.00
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	

Plumbing

Repair/replace kitchen sink	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace kitchen sink faucet	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	350.00
Repair/replace showerhead	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	250.00
Repair/replace tub faucet	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	400.00
Repair/replace toilet	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace lavatory	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace lavatory faucet	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace wash tub	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace wash tub faucet	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Unclog piping:	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair drain/waste/vent piping	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	750.00
Repair water piping	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	350.00
Repair/replace water heater	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	1,300.00
Other	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	permit	\$ 85.00
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	

Windows

Replace broken glass	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair or replace sash	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	\$

Doors

Repair or replace doors	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>		\$	800.00
Repair or repl. locks/latches	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	Self Help	\$	220.00

Walls/Ceilings

Repair or repl. @ defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	1,200.00
-----------------------------	-----	--------------------------	-----	-------------------------------------	----	-----------------

Paint

Repair or repl. @ defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	600.00
-----------------------------	-----	--------------------------	-----	-------------------------------------	----	---------------

Fire Safety

Install smoke/CO alarm:bsmt.	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	Self Help	\$	
Install smoke/CO alarm: 1st flr.	n/a	<input checked="" type="checkbox"/>	Yes	<input type="checkbox"/>	Self Help	\$	
Install smoke/CO alarm: 2nd flr.	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	Self Help	\$	170.00

Handrails

Repair/replace defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	<i>Self Help</i>	\$	125.00
--------------------------	-----	--------------------------	-----	-------------------------------------	------------------	----	---------------

Stairs

Repair defective	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
------------------	-----	--------------------------	-----	--------------------------	----

Floors

Repair defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	750.00
------------------	-----	--------------------------	-----	-------------------------------------	----	---------------

Other

	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$

Interior: Estimated Cost: \$ **39,020.00**

Total Exterior and Interior Cost:* \$ **87,755.00**

*average contracted cost. Actual costs may vary. Self help will reduce the amount.

Inspected by: Jeff Sporer

Date: 8/16/2016

Self Help

Work listed as "self help" means the cost estimate includes only the cost of the materials, not labor or equipment.

Important Information Regarding Permits

All plumbing, heating, electrical, and structural repairs require permits before work can start. Permits are also required for other work such as new siding, new drywall, new doors. Permits are obtained at the Development Center located on the first floor of 809 N. Broadway.

Licensed contractors must do the above work, although owner occupants *may* be eligible to do maintenance work and structural/carpentry repairs.

Owner occupants *may* be eligible to do plumbing work on the unit they live in, but check with the plumbing inspector first.

Generally, minor carpentry repairs, plaster patching, and painting do not require permits.

Anyone disturbing painted surfaces must assume they contain lead paint if the home was built before 1978. Contractors must be licensed to do lead abatement and must obtain a permit. Permits are obtained from the Health Department, located at 7630 W. Mill Road.